

कार्यालय सहायक यंत्री,
लोक स्वास्थ्य यांत्रिकी उपखण्ड, नर्मदापुरम

क्रमांक / 665
प्रति,

/स.य./लो.स्वा.यां./उपखण्ड/2026


नर्मदापुरम, दिनांक....7-9-26

ग्रीन प्वाइंट मांनटेसरी एण्ड स्कूल रैसलपुर
तहसील इटारसी
जिला- नर्मदापुरम

विषय:- पेयजल परिक्षण रिपोर्ट प्रस्तुत करने बावत्।

विषयान्तर्गत आपके द्वारा पेयजल नमूना दिनांक 02.09.2026 को जांच हेतु प्रयोगशाला में दिया गया था, जांच उपरांत पेयजल परिक्षण रिपोर्ट आपकी ओर आवश्यक कार्यवाही हेतु प्रेषित है।

संलग्न:- पेयजल परिक्षण रिपोर्ट


सहायक यंत्री,
लोक स्वास्थ्य यांत्रिकी उपखण्ड
नर्मदापुरम


PRINCIPAL
GREEN POINT
MONTESSORI AND SCHOOL

of Green Point
Montessori and School



DWTLNDPM/F-04 /7.8/F-27



TC - 15038

DISTRICT WATER TESTING LABORATORY

Public Health Engineering Department

Kothi Bazar ,Narmadapuram (M.P) 461001

Test Report

Status of Sample	Drinking Water Sample	Unique Identification NO.	GPMS/GEN/2026/129
Sender's name	Principal Green Point Montessori and School Raisalpur		
Sender's address	Beside MGM School Tehsil Itarsi District - Narmadapuram M.P.	Sender's letter date	02.09.2026
		Start Date of Analysis	02.09.2026
Quantity of sample	1000 ml	DWTL receipt No.	
Sample collected by lab(YES/NO)	No	End Date of Analysis	03.09.2026

Sample details:

S.No	Block	Gram panchyat	Village/Town	Habitation	Location
1	Narmadapuram		Town		Green Point Montessori and School Raisalpur Borewell Water

Physical & Chemical Test Report With Details of Parameters Their Test Methods ,Units and specifications as per BIS.

S. No	Characteristics	Test Method (BIS 10500:2012)	Unit	As per BIS 10500:2012&Reaffirmed in Sep.2018		Test Result				
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Source	Sample Numbers				
						1	2	3	4	5
1	2	3	4	5	6	7				
1	Temperature	°C								
2	Colour	BIS :3025 Part 4	Hazen scale	5	15	2.0				
3	Odour	BIS :3025 Part 5	aggregable			Agg.				
4	Taste	BIS :3025 Part 8	aggregable			Agg.				
5	Iron as Fe	BIS :3025 Part 53	Mg/l	1.0	1.0	0.30				
6	Nitrate as No3	BIS :3025 Part 34	Mg/l	45	45	10.0				
7	Fluoride as F	BIS :3025 Part 60	Mg/l	1.0	1.5	0.10				
8	Chloride as Cl	BIS :3025 Part 32	Mg/l	250	1000	38.0				
9	Total Alkalinity	BIS :3025 Part 23	Mg/l	200	600	338				
10	Calcium as Ca++	BIS :3025 Part 40	Mg/l	75	200	115				
11	Magnesium as Mg	BIS :3025 Part 46	Mg/l	30	100	32.6				


Principal
GREEN POINT
MONTESSORI AND SCHOOL


For Green Point
Montessori and School


Manager

1 2	Total Hardness as CaCO ₃	BIS :3025 Part 21	Mg/l	200	600	424				
1 3 *	Sulphate as SO ₄	BIS :3025 Part 24	Mg/l	200	400	42.4				
1 4	pH	BIS :3025 Part 2	pH scale	6.5 to 8.5	6.5 to 8.5	7.32				
1 5	Turbidity	BIS :3025 Part 10	NTU	1.0	5.0	1.2				
1 6	Conductivity	BIS :3025 Part 14	µmho/cm	-	-	1197				
1 7	TDS	BIS :3025 Part 16	Mg/l	500	2000	778				
1 8 *	Fecal Coliform (TTC)		Per 100 ml	Nil	Nil	0.00				
1 9 *	Total Coliform		Per 100 ml	Nil	Nil	0.00				
2 0	Residual Cl ₂			0.2	1.0	nil				

1. This report should not be produced partly or full without approval of signatory authority for legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but the limit indicated under the "permissible limit in the absence of alternative source" in column 6, above with the sources will have to be rejected.
3. The results refer only to tested Sample and parameter tested.
4. Sample will be stored for a period of 15 days from the date of issue of report (for tests from serial No 1,5,6,7,13,18,19,20).
5. This lab does not hold any responsibility for variation in results for samples kept on hold and want to clarification.
6. The tests marked with an * are not under the process of accreditation by NABL.
7. These sample is potable.


CHEMIST
 DISTRICT WATER TESTING LABORATORY
 P.H.E.D Narmadapuram
 Narmadapuram (M.P.)


PRINCIPAL
 GREEN POINT
 MONTESSORI AND SCHOOL

For Green Point
 Montessori and School

Manager

No. 665

Dated : 03.09.2026

It is certified that an inspection team headed by Shri Anil Sharma (Assistant Engineer) (Name of officers with designation) from P.H.E D Narmadapuram P.H.E Dep. Inspected the **Green Point Montessori and School Beside MGM School Narmadapuram Road Village Raisalpur - Tehsil Itarsi District Narmadapuram M.P.**(Name & Address of the school)on 03.09.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing No. **DWTLNDPM/F-04/7.8/F-27** Dated 03.09.2026 Of District Water Testing Laboratory P.H.E.D Narmadapuram M.P. (PHED LAB) Certified that the **Green Point Montessori and School Beside MGM School Narmadapuram Road Village Raisalpur -Tehsil Itarsi District Narmadapuram M.P.** (Name of school) has safe drinking water facilities for the Students and Members of staff of the institution . School is also maintains the hygienic Sanitation Condition in the school building & the campus as per norms prescribed by the Central /State /U.T Govt.

This certificate is valid till : 02.09.2027

Assistant Engineer
P.H.E. Sub Division
Narmadapuram (M.P.)
Signature with Seal : 
Name Anil Sharma
Designation Assistant Engineer
Name & Address of the office/Department:Narmadapuram

To,


**Green Point Montessori and School Beside MGM School Narmadapuram Road
Village Raisalpur -Tehsil Itarsi
District Narmadapuram M.P.**

.....
(Name&Address of the Institution)

Note:The certificate is to be issued by authorized officer /PHED Lab/Local Bodies


PRINCIPAL
GREEN POINT
MONTESSORI AND SCHOOL

For Green Point
Montessori and School


Manager